



中石化南京催化剂有限公司十二月生产废水监测数据(自测)

监测项目

监测日期	采样地点及监测点 编号名称	总磷 (mg/L)			氨氮 (mg/L)			悬浮物 (mg/L)			TDS (mg/L)			COD (mg/L)		
		污染物浓度 (mg/L)	排放上限 (mg/L)	是否达标	污染物浓度 (mg/L)	排放上限 (mg/L)	是否达标	污染物浓度 (mg/L)	排放上限 (mg/L)	是否达标	污染物浓度 (mg/L)	排放上限 (mg/L)	是否达标	污染物浓度 (mg/L)	排放上限 (mg/L)	是否达标
2021.12.1	进水口	10			52.5									680		
	WS-01-2016	7.3	6-9	是	1.1	≤5	是	2.2	≤45	是	111	≤400	是	1364	≤10000	是
2021.12.2	进水口	/			/									/		
	WS-01-2016	7.5	6-9	是	1.8	≤5	是	8.8	≤45	是	77	≤400	是	2663	≤10000	是
2021.12.3	进水口	10.2			52.9									222	≤500	是
	WS-01-2016	7.4	6-9	是	4	≤5	是	9.1	≤45	是	106	≤400	是	2299	≤10000	是
2021.12.4	进水口	/			/									/		
	WS-01-2016	7.4	6-9	是	0.3	≤5	是	3.6	≤45	是	96	≤400	是	1085	≤10000	是
2021.12.5	进水口	11.4			56.8									145	≤500	是
	WS-01-2016	7.4	6-9	是	2.4	≤5	是	12.4	≤45	是	103	≤400	是	3139	≤10000	是
2021.12.6	进水口	11			115.7									251	≤500	是
	WS-01-2016	7.6	6-9	是	1.8	≤5	是	12.2	≤45	是	100	≤400	是	2508	≤10000	是
2021.12.7	进水口	10.8			157.5									215	≤500	是
	WS-01-2016	7.5	6-9	是	3.3	≤5	是	5.7	≤45	是	86	≤400	是	2355	≤10000	是
2021.12.8	进水口	10.7			227									376	≤500	是
	WS-01-2016	7.4	6-9	是	1.6	≤5	是	5.8	≤45	是	106	≤400	是	5850	≤10000	是
2021.12.9	进水口	10.7			173.4									246	≤500	是
	WS-01-2016	7.6	6-9	是	1.5	≤5	是	8.3	≤45	是	110	≤400	是	7868	≤10000	是
2021.12.10	进水口	10.6			249.8									238	≤500	是
	WS-01-2016	7.6	6-9	是	3.1	≤5	是	22.4	≤45	是	108	≤400	是	2634	≤10000	是
2021.12.11	进水口	10.4			206.5									210	≤500	是
	WS-01-2016	7.6	6-9	是	1.9	≤5	是	7.6	≤45	是	106	≤400	是	2355	≤10000	是
2021.12.12	进水口	10.4			191.6									916		
	WS-01-2016	7.8	6-9	是	1.2	≤5	是	4.9	≤45	是	98	≤400	是	4528	≤10000	是
2021.12.13	进水口	10			89.5									301	≤500	是
	WS-01-2016	7.6	6-9	是	2.6	≤5	是	8.3	≤45	是	96	≤400	是	3040	≤10000	是
2021.12.14	进水口	10.2			150.9									131	≤500	是
	WS-01-2016	7.5	6-9	是	2	≤5	是	12.7	≤45	是	93	≤400	是	6920	≤10000	是
2021.12.15	进水口	9.9			43.1									383	≤500	是
	WS-01-2016	7.6	6-9	是	1.9	≤5	是	15.4	≤45	是	122	≤400	是	5453	≤10000	是
2021.12.16	进水口	/			/									/		
	WS-01-2016	7.6	6-9	是	3.1	≤5	是	12.4	≤45	是	88	≤400	是	4389	≤10000	是
2021.12.17	进水口	/			/									/		
	WS-01-2016	7.5	6-9	是	2.5	≤5	是	16.7	≤45	是	106	≤400	是	5075	≤10000	是
2021.12.18	进水口	9.9			101.7									221	≤500	是
	WS-01-2016	7.2	6-9	是	3.8	≤5	是	15.9	≤45	是	103	≤400	是	4164	≤10000	是
2021.12.19	进水口	9.8			26.3									945		
	WS-01-2016	7.2	6-9	是	0.6	≤5	是	6.3	≤45	是	81	≤400	是	2007	≤10000	是
2021.12.20	进水口	10.5			141.3									40	≤500	是
	WS-01-2016	7.4	6-9	是	3.1	≤5	是	8.4	≤45	是	114	≤400	是	2996	≤10000	是



扫描全能王 创建

2021.12.21	进口	10.9			37.1												353		
	WS-01-2016	7.4	6-9	是	3.1	≤5	是	6.8	≤45	是	116	≤400	是	2646	≤10000	是	180	≤500	是
2021.12.22	进口	/			/												/		
	WS-01-2016	7.5	6-9	是	2.5	≤5	是	7.4	≤45	是	106	≤400	是	2553	≤10000	是	210	≤500	是
2021.12.23	进口	10.3			53.6												836		
	WS-01-2016	7.4	6-9	是	1.6	≤5	是	7.4	≤45	是	120	≤400	是	4561	≤10000	是	352	≤500	是
2021.12.24	进口	10.4			142.8												725		
	WS-01-2016	7.4	6-9	是	1.9	≤5	是	10.1	≤45	是	104	≤400	是	7016	≤10000	是	364	≤500	是
2021.12.25	进口	10.1			140.6												588		
	WS-01-2016	7.4	6-9	是	2	≤5	是	9.8	≤45	是	110	≤400	是	3973	≤10000	是	396	≤500	是
2021.12.26	进口	10.7			112.8												439		
	WS-01-2016	7.4	6-9	是	0.7	≤5	是	7.7	≤45	是	125	≤400	是	6236	≤10000	是	123	≤500	是
2021.12.27	进口	10.5			92.7												358		
	WS-01-2016	7.6	6-9	是	未检出	≤5	是	5.8	≤45	是	119	≤400	是	4123	≤10000	是	154	≤500	是
2021.12.28	进口	/			/												/		
	WS-01-2016	7.6	6-9	是	0.9	≤5	是	9.3	≤45	是	112	≤400	是	2727	≤10000	是	111	≤500	是
2021.12.29	进口	10.4			78.8												2754		
	WS-01-2016	7.5	6-9	是	1.8	≤5	是	8.3	≤45	是	112	≤400	是	1024	≤10000	是	93	≤500	是
2021.12.30	进口	12.6			150												446		
	WS-01-2016	7.9	6-9	是	1.8	≤5	是	6.3	≤45	是	115	≤400	是	1910	≤10000	是	140	≤500	是
2021.12.31	进口	12.4			100.6												554		
	WS-01-2016	7.4	6-9	是	1.9	≤5	是	7.4	≤45	是	106	≤400	是	874	≤10000	是	102	≤500	是

注：/表示无外排，WS-01-2016为污水接管口。



扫描全能王 创建